



DR YS PARMAR UNIVERSITY OF HORTICULTURE & FORESTRY,
NAUNI, SOLAN - 173 230 (HP)

DEPARTMENT OF BIOTECHNOLOGY

Phone: +91 1792 252310

E-mail: hodbtc@yvspuniversity.ac.in

No. UHF/BTC/3-2/- 1006

Dated : 23 . 11 . 2023


SHORT NOTICE INVITING QUOTATION

The sealed quotations are hereby invited by the undersigned for the Automation of Glass house as detailed below:

Sr. No.	Technical Details	Requirement
1	Providing, installation, testing and commissioning of humidification i.e. 16 way fogger with sprinkler as per specifications given: Working pressure: 4 bar, discharge: 7 LPH or less and average particle size : less than 50 micron), LLDPE pipe 16mm, 32mm main PVC pipe, 2 HP pump, 500 Ltr capacity PVC tank, control head assembly, online disc type filtration along with anti leak device to maintain the pressure in the pipe line which prevents leakage during non operation with required fitting and accessories etc.	Work to be done in two separate chambers of equal size {50 sqm each}
2	Providing, installation and testing of 4" thick cellulose cooling pad having a size of 5 mtr x 1.20 mtr along with water circulator system including GI water collecting Gutter PVC water tank 500 Ltr, 1 HP pump with plastic screen filter and fitting & accessories along with MCB, switches, DP isolator and conduit pipe in copper wiring	
3	Providing and fixing shade net 50% shading capacity	
4	AUTOMATION AND CONTROLLING SYSTEM IN BOTH CHAMBERS	

Conditions :

- 1 Price including installation (GST inclusive) may be quoted.
- 2 The quotation forms shall be issued only to those Contractors who have sufficient experience and competence to execute the above mentioned works on production of proof thereof and they have to produce the income tax/GST Registration Certificates alongwith PAN number.
- 3 The quotation should be addressed to the undersigned and should reach by **11/12/2023 at (5:00 PM) positively**. The last date for receipt of the quotations should be mentioned on the top of the envelope (only hard copy of quotation will be accepted)
- 4 The quotation received after the due date will not be considered.
- 5 The rates quoted should be F.O.R. Nauni.-Solan (HP).
- 6 The price should strictly be adhered to the technical specifications mentioned above.
- 7 Warranty for **two years** minimum for the work to be done.


23/11/2023
Head